



NOTE:
 NO OBSTRUCTIONS SUCH AS PEDESTALS,
 FENCES, BUILDINGS, OR BUSHES ARE TO
 EXIST WITHIN THREE FEET (3') FROM SIDES
 AND REAR OF PAD-MOUNTED TRANSFORMER.
 THERE MUST BE AT LEAST TEN FEET (10')
 CLEARANCE FROM FRONT OF TRANSFORMER
 OR A GATE ALLOWING ACCESS TO THE
 LOCKED FRONT OF TRANSFORMER.

PUB.DATE: 08/01/12

PAD-MOUNTED TRANSFORMER CLEARANCE SPECIFICATIONS	(20) OZARK ELECTRIC COOPERATIVE MT. VERNON, MISSOURI	
	DRAWN BY: DWB	DATE: 07/22/04
	CHECKED BY: KMR	SCALE: NONE
	APPROVED BY:	FENCE-SPEC